BAFE SP 203 | NICEIC APPROVED CONTRACTOR | SSAIB

rgeservices ltd

SERVICE/MAINTENANCE CERTIFICATE

Job No. 108975

Customer: kc

Date: 7/2/14

Site Address: Greenfell towers

Yearly Inspection		Quarterly Inspection	✓	Breakdown		Service	✓

Description of Work: Service to BS 5839

ITEM/DESCRIPTION	YES	NO	ITEM/DESCRIPTION	YES	NO
Are Drawings Current	✓		Number of Loops/Zones in Use	27 zones	
Battery Date	June 2010		Alarms Sounded	✓	
Battery Voltage (indicate)	27.5 V		Fire Risk Ass Available	✓	
Zone E.O.L. Monitor Fitted Correctly	(1)	✓	Dedicated Supply	✓	
Alarm E.O.L. Monitor Fitted Correctly		✓	Zone Chart Displayed	✓	
Power Fault Monitor Mains Removed	✓		Panel Indicators/Buzzers	✓	
Power Fault Monitor Battery Removed	✓		Detector Head Removed	✓	
Cause & Effects	✓		Devices Labelled		✓
Building Use or Layout Changed		✓	Device Age/Estimate if not marked	various (3)	
Remote Monitoring Connected	✓	(2)	No. of False Alarms per 100 Detectors		

SYSTEM DESCRIPTION	IF YES, TYPE	SYSTEM DESCRIPTION	IF YES, TYPE
Main Panel	kentec conventional	Door Magnets	window vents
Repeater Panel/Network	N/A	Sounders/Bells/Voice	24v Bells
Break Glass	KAC Conventional	Beacons	N/A
Batteries	yuasa 12 v 17 Ah Qty 2	Input/Output Units (4)	vent control + lift recall
Smoke Detector	Apollo conventional (3)	Cable Type	FP200 + M1
Fixed/ROR Heats	Apollo	**UPDATED LOG BOOK**	Yes

Category of System	P1		P2		M		L1		L2		L3		L4		L5	
Battery Calculations	Standby	x	Time	+	In Alarm	x	Batt Def	=	•	Ah required						
Results Recorded	• 32 (mA)		12 (hrs)	+	1 • 4 (mA)	x	1.25	=	6 • 6 (Ah)							

Devices Checked and Location:

Checked and tested 25% of devices.

Notes:

Panel in full working order on arrival. (1) E.O.L monitors are fitted in panel. (2) Panel is monitored via Install call point located in office. (3) Age of devices range from 2007 + 2009 to pre 1988. (4) I/O units to open window and shut lift down are located in riser next to office on ground floor.

Next Test Due Date: 3 months.

Time on Site :	Time off Site :	I/We certify the engineer has carried out work as stated
Signature (Engineer):		**Signature (Client):**
Name in Capitals (Engineer): S. CHANDLER		**Name in Capitals (Client):**

(WHITE COPY = OFFICE) (PINK COPY = SITE)

19-21 Roebuck Road, Hainault Business Park, Ilford, Essex IG6 3TU Tel: [redacted] Info@rgeservices.co.uk