

Message

From: Wisken, Martyn [Martyn.Wisken@triio.co.uk]
Sent: 24/11/2016 15:30:23
To: Charlie Saul [csaul@kctmo.org.uk]; Smith, Harvey [Harvey.Smith@triio.co.uk]
Subject: RE: IMG170186 - GRENFELL TOWER

Charlie,

The intention is that the boxing will isolate the pipework from the mechanical ventilation in the communal areas. It will be vented directly to the stairwell at one end (which itself is well ventilated) and run to a "dead end" at the point of entry to the individual flats at the other. In case of fire in the stairwell, any smoke will travel along the boxing to a dead end and would be isolated within the boxing. In turn any smoke within the communal area would not get to the stairwell as the boxing would be fire rated.

Hope this helps.

Regards

Martyn Wisken
Design Engineer
tRIIO®
Uxbridge Road,
Slough.
SL2 5NA
Phone: [REDACTED]
Mobile: [REDACTED]

tRIIO® is a joint venture partnership between Morrison Utility Services and Skanska Construction UK.
A gas distribution strategic partner.

The information contained in this message is likely to be confidential and may be legally privileged. It is intended solely for the use of the individual or entity to which it is addressed. If you have received this message by mistake, please let us know immediately by replying to this email and then delete all copies of the email from your system. If you are not the intended recipient you must not disclose, distribute, copy, print or rely on this email.

Whilst we have taken reasonable precautions to ensure that this email and any attachments have been checked for viruses we cannot guarantee that they are virus free and we cannot accept liability for any damage sustained as a result of software viruses. We would advise that you carry out your own virus checks especially before opening an attachment.

tRIIO® cannot accept any responsibility for the accuracy or completeness of this email and unless otherwise expressly stated does not authorise any contract to be made by email. tRIIO® may recall, delete and monitor all outgoing and incoming emails.

Morrison Utility Services Limited

Registered Office: Morrison House, Primett Road, Stevenage, Herts, SG1 3EE
Registered in England. Company Number 4530602

Skanska Construction UK Limited

Registered Office: Maple Cross House, Denham Way, Maple Cross, Rickmansworth, Herts, WD3 9SW
Registered in England. Company Number 191408

Please consider the environment before printing this email.

From: Charlie Saul [mailto:csaul@kctmo.org.uk]
Sent: 24 November 2016 13:05
To: Smith, Harvey
Cc: Wisken, Martyn
Subject: RE: IMG170186 - GRENFELL TOWER

Good afternoon Harvey,

I'm wondering if you could please answer a couple of queries with regards to the boxing around the pipework to be installed?

- What is the finish to the boxing?
- How will the boxing affect the fire safety of the block?

With regards to fire safety we are querying if the boxing will compromise the compartmentation of the stairs/lobby areas. It's not clear from the plans if the boxing will end in the lobby or continue into the stairwell. The worry is that if the boxing continues into the stairwell then this will allow the passage of smoke through the block.

How could the flow of smoke be controlled within the open ended boxing?

Hope this makes sense.

Kind regards,


Charlie

Charlie Saul
Contracts Manager
Assets and Regeneration
Kensington & Chelsea TMO


csaul@kctmo.org.uk



www.kctmo.org.uk



292a Kensal Road, London, W10 5BE

 Before printing, please think about the environment

From: Smith, Harvey [<mailto:Harvey.Smith@triio.co.uk>]

Sent: 18 November 2016 14:08

To: Charlie Saul <csaul@kctmo.org.uk>

Cc: Wisken, Martyn <Martyn.Wisken@triio.co.uk>

Subject: FW: IMG170186 - GRENfell TOWER

Charlie

Please find the attached design for the above. I have been advised that buy-out is not an option for this block, so would be grateful if you could review the design and confirm whether permission will be granted to complete the works.

Regards

Harvey Smith

Operations Support Manager

tRIIO®

National Grid

Albert Road

East Barnet

EN4 9SH

Phone: [REDACTED]

Email: harvey.smith@triio.co.uk



From: Johnson, Ashley **On Behalf Of** MOBS, NL

Sent: 15 November 2016 16:02

To: MOBS, NL; Cave, Vince; Raif, Aytac; Murray, Michael; Bender, Ronald; Hassan, Ertan; Hasan, Alpaslan; Walton, Sinclair; Tjonis, Anthony; Richardson, Adam; O'Kane, Peter; Gerreyn, Cedric; Mehmet, Michelle; Pretty, Ian; Gordon, Nicholas; Brown, Natalie; Sutherland, Graham; Keeley, Philomena; Boyle, Simon; Lovett, Hugh; Blaker, Stephen; Radley, Andrew; Donovan, Stephen; Burder, Jayne; Kinden, Trevor; Cox, Michael; Page, Mike; Burr, Timothy; MOBS Commercial; Grant, Richard; Hall, Dave; Gosney, Gemma; Weaver, Michael; Barton, Natalie; Crawley, Paul; Guest, Mavis; Tattam, Janet; Hounsom, Carol; Estcourt, Andrew; Savage, Robin; Winand, Stephen; Croucher, Hannah; Watkinson, Amy; Umagho-Ukueku, Michelle; Dolan, Aaron; Huntley, Paul; Sayles, Leonard; Johnson, Edward

Cc: Clarke, Steve; Cassin, Dave; Deardon, Denise; Hoskins, Ian; Smith, Harvey; Steele, Ryan; Stevens, Stuart (Borehamwood); Talbot, Cerianne; Kingston, Nathan; Weaver, Michael

Subject: IMG170186 - GRENELL TOWER

All

Please see attached the design pack for the above project

Regards

Ashley Johnson

Design Analyst

tRIIO®

Office: Uxbridge Road

Slough

Berkshire

SL2 5NA

Mobile: [REDACTED]



tRIIO® is a joint venture partnership between Morrison Utility Services and Skanska Construction UK.
A gas distribution strategic partner.

TMO10015271/3
TMO10015271_0000

The information contained in this message is likely to be confidential and may be legally privileged. It is intended solely for the use of the individual or entity to which it is addressed. If you have received this message by mistake, please let us know immediately by replying to this email and then delete all copies of the email from your system. If you are not the intended recipient you must not disclose, distribute, copy, print or rely on this email.

Whilst we have taken reasonable precautions to ensure that this email and any attachments have been checked for viruses we cannot guarantee that they are virus free and we cannot accept liability for any damage sustained as a result of software viruses. We would advise that you carry out your own virus checks especially before opening an attachment.

tRiIO® cannot accept any responsibility for the accuracy or completeness of this email and unless otherwise expressly stated does not authorise any contract to be made by email. tRiIO® may recall, delete and monitor all outgoing and incoming emails.

Morrison Utility Services Limited

Registered Office: Morrison House, Primett Road, Stevenage, Herts, SG1 3EE
Registered in England. Company Number 4530602

Skanska Construction UK Limited

Registered Office: Maple Cross House, Denham Way, Maple Cross, Rickmansworth, Herts, WD3 9SW
Registered in England. Company Number 191408

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.