

Message

From: [REDACTED]
Sent: 25/05/2016 10:49:48
To: jwray@kctmo.org.uk; Janice Wray ["/O=KC TMO/OU=First Administrative Group/cn=Recipients/cn=jwray"]
Subject: Re: Grenfell Tower - Minutes from meeting with Building Control - 7th Jan 2016

All noted

In 2.03 it states:

BC do not require heat detectors to kitchens of flats on mezzanine level as escape corridor is under 9m long

There is no mention of travel distances in BS 5839 Part 6, only the standard of installed fire alarm system needed to provide suitable coverage to the dwelling, ie LD1, LD2 or LD3, the other floor level has the highest possible standard of coverage LD1, detection in every room as far as I can tell. But on this floor level only the lowest standard of coverage has been provided, with no heat detector in the kitchens.

There is no consistency here as the occupants on one floor level have the highest standard of system fitted and the occupants of the dwellings on the other floor have a lower standard of fire detection coverage.

The recent TMO programme of fitting domestic detection in existing dwellings has an LD 2 system being installed. Smoke detection in the hallways, the means of escape route and heat detection in the kitchens, the high risk area.

I agree that the Max Fordham drawing do not show a heat detector in the kitchen areas of these dwellings, but these drawings also show an office area where there is now an apartment, so these drawings are not up to date.

On this point can the drawings for the Walkway level Plus 1 be provided to see what Part 6 detection was to be installed within those dwellings?

I would recommend that the Building Control Officer is contacted and asked where this 9 metre rule has come from as there is no mention of travel distances in BS 5839 Part 6 only the standard to be installed after undertaking the design criteria matrix in clause 4 of the document.

As the Building Control Department of RBKC are signing off this project then they are taking responsibility for this matter, this item has been raised and due diligence undertaken by the TMO.

Carl

-----Original Message-----

From: Janice Wray <jwray@kctmo.org.uk>

To: carlstokes [REDACTED]

Sent: Wed, 25 May 2016 09:08:01

Subject: FW: Grenfell Tower - Minutes from meeting with Building Control - 7th Jan 2016

FYI – heat detector issue

Janice

From: David Hughes [mailto:dhughes@rydon.co.uk]

Sent: 25 May 2016 06:18

To: Claire Williams; Janice Wray

Cc: Mike Brown; Steve Blake

Subject: FW: Grenfell Tower - Minutes from meeting with Building Control - 7th Jan 2016

Hi Claire & Janice

Following our FRA meeting yesterday, please see confirmation e-mail below from Paul Hanson regarding

acceptance of minutes from design team meeting held back in January.

I've attached the meeting minutes for your information – heat detectors to 1st floor flats is item 2.03

I've also attached the Max Fordham design drawings which also have no heat detectors to kitchens on 1st floor.

Any questions, please give me a call

Kind regards

Dave

David Hughes
Site Manager
T
M

[REDACTED]

From: Paul.Hanson@rbkc.gov.uk [mailto:Paul.Hanson@rbkc.gov.uk]
Sent: 13 January 2016 11:46
To: David Hughes
Cc: clwilliams@kctmo.org.uk; ncil.recd@uk.arteliagroup.com; andrew.malcolm@uk.arteliagroup.com; tbatty@silcockdawson.co.uk; jwhite@jrp.co.uk; M.Smith@maxfordham.com; JonathonEarl@jswright.co.uk; andy@rjelectrics.co.uk; alanwhyte@jswright.co.uk; [REDACTED]; richardmoss@jswright.co.uk; DavidBradbury@jswright.co.uk; James Clifton; Neil@studioe.co.uk; Steve Blake; John.Hoban@rbkc.gov.uk
Subject: RE: Grenfell Tower - Minutes from meeting with Building Control - 7th Jan 2016

Dear Dave,

I have reviewed the minutes and confirm they are accurate regarding my reference (means of escape). In addition John Hoban (RBKC building control) did also mention about fire stopping particularly above door frames.

Regards
Paul Hanson
Senior Building Control Surveyor (Fire Regulations)
Royal Borough of Kensington and Chelsea
T. [REDACTED]
M. [REDACTED]
F. [REDACTED]
W. www.rbkc.gov.uk/buildingcontrol

From: David Hughes [mailto:dhughes@rydon.co.uk]
Sent: 08 January 2016 15:53
To: Steve Blake; Neil@studioe.co.uk; Hoban, John: CP-Plan; Hanson, Paul: CP-Plan
Cc: 'Claire Williams' (clwilliams@kctmo.org.uk); Neil Reed (neil.reed@uk.arteliagroup.com); MALCOLM

Andrew (andrew.malcolm@uk.arteliagroup.com); Batty, Tony (tbatty@silcockdawson.co.uk); 'Jon White' (jwhite@jrp.co.uk); M.Smith@maxfordham.com; JonathonEarl@jswright.co.uk; andy@rjelectrics.co.uk; alanwhyte@jswright.co.uk; [REDACTED] richardmoss@jswright.co.uk; David Bradbury <DavidBradbury@jswright.co.uk> (DavidBradbury@jswright.co.uk); James Clifton
Subject: Grenfell Tower - Minutes from meeting with Building Control - 7th Jan 2016

Dear All

Please see minutes attached from recent meeting with Building Control at Grenfell Tower

John & Paul – Please can you respond if you have comments about the minutes ?

Any questions, please give me a call

Kind regards

Dave

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>

Nominations sought for Mayor's Awards

If you know someone who has made an outstanding contribution to the life of the Royal Borough then nominate them for an award and tell us why they are special.

<http://www.rbkc.gov.uk/mayorsawards>

RBKC Local App

Noticed a streetlight that isn't working? Want to report fly tipping? Use the RBKC Local App to report it, register for it, pay for it.

<http://www.rbkc.gov.uk/RBKCLocal>

The Royal Borough of Kensington and Chelsea.

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>

This e-mail message has been scanned for Viruses and Content and cleared by MailMarshal

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.