
From: Bruce Sounes <bruce@studioe.co.uk>
Sent: 23 May 2014 14:54
To: Claire Williams; slawrence@rydon.co.uk
Cc: Marc Watterson; Mark Harris
Subject: Grenfell - Brushed aluminium
Attachments: 140523 Grenfell Cladding VE.pdf

Dear All,

I stopped by the housing development in Kilburn first thing today and have uploaded pictures here:

[Picasa web album](#)

The brushed aluminium (Natural Aluminium Brushed H 9103 S) looks very good. The appeal relies also on the deep shadow joints, and I think the vertical joints channel rainwater run-off thereby keeping the faces cleaner. The natural aluminium seems to have picket up less dirt than the painted panels. It is very reflective but I don't think it will get glare complaints.

If we send the Planners to see the example they will jump on the fact it is clean of all face fixings, with rivets mostly concealed in return faces to the joints. I know you have prepared cost options to do this but I've prepared a sketch, attached showing how the ACM could be assembled as cassettes or perhaps as a hybrid which I'm less convinced by.

I think the brushed aluminium cassette will be accepted by Planners.

Regards

Bruce Sounes

For and on behalf of
STUDIO E LLP

Palace Wharf, Rainville Road, London W6 9HN
T [REDACTED] | M [REDACTED] | www.studioe.co.uk