

Message

**From:** Smith, Harvey [/O=AWGPLC/OU=FIRST ADMINISTRATIVE GROUP/CN=RECIPIENTS/CN=SMITH, HARVEY]  
**Sent:** 10/02/2017 10:41:41  
**To:** Charlie Saul [csaul@kctmo.org.uk]  
**CC:** Loveday, Martin [/O=AWGPLC/OU=First Administrative Group/cn=Recipients/cn=Loveday, Martin]; Wisken, Martyn [/O=AWGPLC/OU=First Administrative Group/cn=Recipients/cn=Wisken, Martyn]  
**Subject:** RE: Grenfell Tower - Reinstatement Works

Charlie

Please see responses below:-

1. As structural work is being undertaken within this building as part of this project

has a Building Regulations application been made for the work/project?

TRIIO has not been requested to submit a Building Regulations application for these works and this has not previously been requested for our works.

2. All holes in compartment wall must be suitably fire stopped using fire rated

materials of a minimum of 90 minutes fire rating.

Once the pipe network is installed we will box in to provide fire protection and seal holes that are not needed to provide a flow of air through the boxed sections.

3. Documentation should be provided by the gas contractor showing the fire rated

materials used for the fire stopping of the compartment walls and the fire rating of

the fire collars used.

On completion of our works we will provide documentation to confirm the fire worthiness of our installation.

Regards

Message

**From:** Smith, Harvey [/O=AWGPLC/OU=FIRST ADMINISTRATIVE GROUP/CN=RECIPIENTS/CN=SMITH, HARVEY]  
**Sent:** 10/02/2017 10:41:41  
**To:** Charlie Saul [csaul@kctmo.org.uk]  
**CC:** Loveday, Martin [/O=AWGPLC/OU=First Administrative Group/cn=Recipients/cn=Loveday, Martin]; Wisken, Martyn [/O=AWGPLC/OU=First Administrative Group/cn=Recipients/cn=Wisken, Martyn]  
**Subject:** RE: Grenfell Tower - Reinstatement Works

Charlie

Please see responses below:-

1. As structural work is being undertaken within this building as part of this project

has a Building Regulations application been made for the work/project?

TRIIO has not been requested to submit a Building Regulations application for these works and this has not previously been requested for our works.

2. All holes in compartment wall must be suitably fire stopped using fire rated

materials of a minimum of 90 minutes fire rating.

Once the pipe network is installed we will box in to provide fire protection and seal holes that are not needed to provide a flow of air through the boxed sections.

3. Documentation should be provided by the gas contractor showing the fire rated

materials used for the fire stopping of the compartment walls and the fire rating of

the fire collars used.

On completion of our works we will provide documentation to confirm the fire worthiness of our installation.

Regards

Harvey Smith

Operations Support Manager

tRiIO®  
National Grid

Albert Road  
East Barnet

EN4 9SH

Phone: [REDACTED]

Email: [harvey.smith@trio.co.uk](mailto:harvey.smith@trio.co.uk)



**From:** Charlie Saul [mailto:csaul@kctmo.org.uk]

**Sent:** 31 January 2017 14:51

**To:** Smith, Harvey

**Cc:** Radley, Andrew

**Subject:** Grenfell Tower - Reinstatement Works

Good afternoon Harvey,

Please see the report attached from our Fire Risk Assessor.

Could you please provide comments and assurances to the points raised?

Kind regards,

Harvey Smith

Operations Support Manager

**triiO®**  
National Grid

Albert Road  
East Barnet

EN4 9SH

Phone: [REDACTED]

Email: [harvey.smith@trii.co.uk](mailto:harvey.smith@trii.co.uk)



**From:** Charlie Saul [mailto:[csaul@kctmo.org.uk](mailto:csaul@kctmo.org.uk)]

**Sent:** 31 January 2017 14:51

**To:** Smith, Harvey

**Cc:** Radley, Andrew

**Subject:** Grenfell Tower - Reinstatement Works

Good afternoon Harvey,

Please see the report attached from our Fire Risk Assessor.

Could you please provide comments and assurances to the points raised?

Kind regards,

Charlie

Charlie Saul

Contracts Manager

Assets and Regeneration

Kensington & Chelsea TMO

[csaul@kctmo.org.uk](mailto:csaul@kctmo.org.uk)

[REDACTED]


[REDACTED]



[www.kctmo.org.uk](http://www.kctmo.org.uk)

[REDACTED]

292a Kensal Road, London, W10 5BE

 Before printing, please think about the environment.

---

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

---

**DISCLAIMER:**

PI-001-00757  
TRI000000757 0005  
**TRI000000757/5**

Charlie

Charlie Saul

Contracts Manager

Assets and Regeneration

Kensington & Chelsea TMO

[csaul@kctmo.org.uk](mailto:csaul@kctmo.org.uk)

[REDACTED]


[REDACTED]



[www.kctmo.org.uk](http://www.kctmo.org.uk)

[REDACTED]

292a Kensal Road, London, W10 5BE

 Before printing, please think about the environment.

---

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

---

**DISCLAIMER:**

PI-001-00757  
TRI000000757 0006  
**TRI000000757/6**

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd. accepts no liability for any damage caused by any Virus transmitted by this email.

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd. accepts no liability for any damage caused by any Virus transmitted by this email.