

SSHD/1



Department for
Communities and
Local Government

Melanie Dawes CB
Permanent Secretary

Department for Communities and Local
Government
2 Marsham Street
London SW1P 4DF

Tel: [REDACTED]
[REDACTED]@communities.gsi.gov.uk
www.gov.uk/dclg

To Local Authority Chief Executives and
Housing Association Chief Executives
By Email

22 June 2017

Safety checks following Grenfell Tower fire

Thank you all for your continued work following the appalling tragedy in North Kensington. Our priority must continue to be checking on the safety of buildings and listening to and being open with residents, and reassuring them as much as possible.

My letter of 18 June asked that local authorities and other registered providers of social housing identify whether any panels used in new build or refurbishment are of a particular type of cladding made of Aluminium Composite Material (ACM).

The testing process for samples of cladding is underway and the attached note sets out the action that an independent panel of experts advise must immediately be taken if it is determined that the insulation within Aluminium Composite Material (ACM) is unlikely to be compliant with the requirements of the current Building Regulations. This advice has been endorsed by the National Fire Chiefs Council who will be circulating it separately to their members.

These interim mitigating measures must immediately be implemented to ensure the safety of residents, pending replacement of the cladding.

If you have any questions about the testing process for the cladding please email housingchecks@communities.gsi.gov.uk

If you have questions about the advice on action which needs to be taken please contact safetychecks@communities.gsi.gov.uk.

Yours sincerely

MELANIE DAWES

Annex A: EMERGENCY FIRE SAFETY REVIEW

If it is determined that the insulation within Aluminium Composite Material (ACM)¹ is unlikely to be compliant with the requirements of the current Building Regulations guidance, it is essential that you **immediately** implement the following interim mitigating measures to ensure the safety of residents, pending replacement of the cladding.

Interim measures recommended by independent panel of experts

Notify Fire and Rescue Service.

Inform your local fire and rescue service fire safety/protection department. Failure to do so may put fire-fighters as well as residents at risk. The fire and rescue service will carry out an urgent inspection with the 'responsible person' to ensure that they are identifying and introducing appropriate interim measures, as set out below. The fire service will carry out a further inspection once the interim measures have been completed:

- Check that the fire risk assessment has been carried out within the previous 12 months and that the recommendations within the action plan of the assessment have been completed; also, confirm that there have been no material changes (to the building, the fire safety measures or the occupancy) that could, potentially, undermine the validity of the fire risk assessment. If no fire risk assessment has been carried out, you must **immediately** arrange for a fire risk assessment to be carried out by a competent person (eg by a person who is listed on a register of fire risk assessors operated by a professional body or certification body, or, preferably, by a company that is certificated by a third party certification body, that is, itself, accredited by the United Kingdom Accreditation Service to operate the certification scheme). Guidance on choosing a competent assessor is here <http://www.cfoa.org.uk/19532>
- Engage with residents to ensure they fully understand the emergency fire procedures in the building, particularly the meaning of "stay put". Ensure that fire procedure notices are accurate.
- Check that, at ground level, or on any balconies, there are no combustible materials (eg storage of refuse) in the vicinity of the cladding. Ensure that there are measures to prevent combustible materials in such locations (eg by temporary barriers or instructions to residents). Instruct residents that they must not have any barbeques on any balcony.
- Check that all flat entrance doors, and doors that open onto escape corridors and stairways, are fire-resisting and effectively self-closing against any resistance of a latch (or, for example, in the case of plant rooms or cupboards, are kept locked shut.) For guidance on these doors, consult the Local Government Association guidance on fire

¹ For the avoidance of doubt; the core (filler) within an Aluminium Composite Material (ACM) is an "insulation material/product", "insulation product", and/or "filler material" as referred to in Paragraph 12.7 ("Insulation Materials/Products") in Section 12 "Construction of external walls" of Approved Document B (Fire safety) Volume 2 Buildings other than dwelling houses. (The important point to note is that Paragraph 12.7 does not just apply to thermal insulation within the wall construction, but applies to any element of the cladding system, including, therefore, the core of the ACM).

safety in purpose-built blocks of flats – <https://www.local.gov.uk/fire-safety-purpose-built-flats> - but, in general, doors that were deemed to be fire-resisting at the time of construction of the block will be satisfactory. Replace any non-fire-resisting doors (such as non-fire-resisting upvc doors) immediately with doorsets (i.e. doors and frames) that are third party certificated as providing at least 30 minutes fire resistance.

- Check all walls that separate flats, plant and store rooms, etc from escape routes to ensure there are no obvious routes for fire or smoke spread (eg, holes where services, such as pipes and cables, pass through walls).
- Check that any smoke control systems, including associated fire detection systems, are operating correctly.
- Check all facilities provided for fire-fighters, including fire-fighting lifts and dry or wet rising mains. If you have **ANY** concerns you should contact your local fire and rescue service, who will, if they have not already done so, carry out an inspection to ensure functionality.
- Ensure that there is sufficient roadway access and hardstanding for firefighting vehicles attending incidents and to be set up to fight any fire externally.
- Check that insulation or other materials that form the façade meet all relevant standards.

If the building is protected by an automatic sprinkler system (or equivalent fire suppression system) you might not need to take any further interim measures before replacement of the cladding.

If the building is not protected by a suitable suppression system you must consider the need for interim measures. The measures adopted need to be based on an assessment of the risk by a competent person, but the following must, at least, be considered:

- Residents to be advised to ensure all smoke alarms are present and working in their flat; to report concerns about fire safety measures in the building (eg presence of combustible materials in escape routes) to their landlord and, understand the purpose of any interim measures being taken.
- Closure of car parks in which a vehicle fire could impinge on cladding.
- Provision of a temporary communal fire alarm system, comprising smoke detectors in circulation areas and plant rooms, and fire detectors (possibly heat detectors, rather than smoke detectors) in conjunction with fire alarm sounders in each flat. This will enable the entire block to be evacuated simultaneously in the event of fire. This option is unlikely to be suitable for tall blocks, in which a large number of people would need to use escape routes at the same time. The system may comprise a wireless system, using radio to link devices.
- Provision of a fire watch by appropriately trained patrolling security officers/wardens.

- In the case of the most serious risk, consideration must be given to moving all residents out of the block until satisfactory remedial work has been done.

SSHD/2



NFCC
National Fire
Chiefs Council

The professional voice of the UK Fire & Rescue Service

Waking Watch / Common Fire Alarm

**Guidance to support a temporary simultaneous evacuation strategy in a
purpose-built block of flats**

Contents

1.	Introduction	3
2.	Definitions	5
3.	Competence	6
4.	Changing the evacuation strategy	7
5.	Management considerations to support the adoption of an evacuation strategy	8
6.	Responsible person duties	11

Appendices

1.	Waking watch guidance.....	11
2.	Common alarm system.....	13

This guidance note provides advice to building owners, their professional advisors and fire and rescue services on issues to consider where a decision is made, based on a comprehensive risk assessment carried out by a competent person, to suspend temporarily a stay put policy and adopt a simultaneous evacuation strategy.

Although written for those responsible for the safety of residents in purpose-built blocks of flats, the principles of this guidance may, in certain circumstances, be applied to other premises.

1. Introduction

- 1.1. The NFCC supports the 'Fire safety in Purpose Built Block of Flats' guidance hosted on the LGA website and developed by a wide range of stakeholders. The guidance remains appropriate for all purpose built blocks of flats. However, the unique circumstances following the Grenfell Tower fire mean that Section 19 in particular 'Stay put policy', and in particular paragraphs 19.6 and 19.7, should be considered in the context of this additional and complementary guidance.
- 1.2. NFCC support the principle of a stay put strategy whenever possible, as it has been proved over many years to be safe for residents of purpose-built blocks of flats. This guidance provides fire safety advice in respect of purpose-built blocks of flats where a stay put strategy was part of the original design and is no longer considered appropriate owing to significant failings in the general fire precautions, and a temporary change to a simultaneous evacuation strategy is likely to be necessary until the failings have been rectified.
- 1.3. This guidance, which applies to premises in England and Wales, is produced to support the fire and rescue service (FRS), building owners/responsible persons and associated fire safety specialists, including fire risk assessors, at buildings that have been fitted with an external wall system that has failed the large scale tests that were commissioned by the Department for Communities and Local Government following the Grenfell Tower fire, and that were carried out at the Building Research Establishment (BRE).
- 1.4. The guidance sets out the context and decision-making considerations in moving from a stay put to simultaneous evacuation strategy. It includes appendices that set out further guidance on the Waking Watch and Common Fire Alarm systems that are appropriate.
- 1.5. The fire safety strategy in purpose-built blocks of flats normally comprises an arrangement whereby only residents from flats directly affected by fire, heat or smoke need evacuate. Residents in other, unaffected flats should be protected by general fire precautions provided in the building, such as the structure of the building, the front doors of individual flats, smoke ventilation provisions, etc. Those other residents should therefore be safe to 'stay put' during a fire in their building unless otherwise directed by the FRS, and, in many cases, may not even be aware of a fire elsewhere in the building.
- 1.6. The fire alarm arrangements in purpose-built blocks of flats typically include smoke (and sometimes heat) alarms within each flat to alert the residents of a fire in that flat only. There is generally no common fire alarm system.
- 1.7. Where fire detectors are installed in the common parts, they are likely to be provided only to operate active fire safety facilities such as a smoke control system. The detectors are not provided to give a warning to all residents in the building.
- 1.8. Where there is a significant failing in the general fire precautions, a competent fire safety specialist may consider that these failings could contribute to uncontrolled and, potentially, unrestricted fire spread in the building, and therefore the building can no longer support a stay put strategy. A temporary change to a simultaneous evacuation strategy may provide a level of confidence that, whilst there are clear risks that must be addressed, continued occupation of the building is possible with the adoption of a change to an evacuation strategy and a clear definition of the management strategy of the building, which should be communicated to residents.

- 1.9. Whilst this guidance has been developed specifically for high rise residential premises that require a change to the evacuation strategy to be adopted until fire safety defects are rectified, some of this guidance may be applied to other building uses (e.g. a hotel or hospital) or for other outcomes (e.g. only for a guaranteed immediate call to the fire service but without a simultaneous evacuation). In those cases, some of this guidance may be of assistance if adapted to those needs

2. Definitions

Assembly point

- 2.1. A designated place where people have been told to wait after evacuating a building in the event of a fire or other emergency.

Note: An alternative assembly point that has protection against inclement weather may be required.

Common Parts

- 2.2. Those areas of a building that are not for the exclusive use of individual residents (e.g. common corridors, stairways, plant rooms, other ancillary areas, etc.).

Common fire alarm system

- 2.3. A fire alarm system that will give a warning of fire throughout the building, including within all flats and within the common parts.

Competent person

- 2.4. Please refer to section 3 for further detail.

Evacuation

- 2.5. A process whereby people leave premises in case of an incident.

External wall system

- 2.6. External construction of a building including external walls, cladding, insulation, filler materials, etc.

General fire precautions

- 2.7. This term is used to describe precautions that are provided to reduce the risk of fire and spread of fire, in conjunction with other measures, to keep people safe from fire in a building (see Article 4 of the Regulatory Reform (Fire Safety) Order 2005).

Interim mitigation measures

- 2.8. Urgent temporary measures which are to be put in place where there is an unacceptable risk to occupants of a building.

Personal emergency evacuation plan (PEEP)

- 2.9. A documented plan for the evacuation of people who may not be able to self-evacuate, are slower to evacuate or require some assistance to do so.

Responsible person

- 2.10. The person, group, company or other entity on whom duties are imposed by the Regulatory Reform (Fire Safety) Order 2005 to ensure the safety of occupants of a building from fire (see Article 3 of Regulatory Reform (Fire Safety) Order 2005).

Simultaneous evacuation

- 2.11. Procedure in which all parts of a building are evacuated in the event of fire.

Smoke ventilation system

- 2.12. A system to control and/or prevent the spread of smoke in protected routes in the event of fire. The primary objective of a smoke ventilation system is to protect the common parts. These areas may exist on the floor level where the fire has originated and in stairwells, enabling those occupants who feel threatened or who are at greatest risk to escape. Such systems will further assist firefighters to gain access.

Sounder

- 2.13. A device that will give an audible warning in the event of fire.

Stay put strategy

- 2.14. A strategy based on the principle that only the residents of the flat of fire origin need to escape initially, while other residents may remain in their own flats unless their flat is affected by fire or smoke, they feel threatened, or they are instructed to leave by the FRS. A stay put strategy does not preclude residents, who are aware of a fire within the building but not affected directly by it, from deciding to evacuate.

Waking watch (also referred to as a fire watch)

- 2.15. A system whereby staff continually patrol all floors and the exterior perimeter of the building to maintain safety of occupants of the building from fire.

3. Competence

- 3.1. The complexity of the interactions between people, buildings and fire is such that no single set of criteria can be applied to all types of buildings in all circumstances. Therefore, an assessment, specific to the building in question, will need to be conducted that considers any potential fire spread in conjunction with the evacuation strategy and any modifications to that strategy (i.e. a change from a stay put to a simultaneous evacuation strategy).
- 3.2. The advice used to inform this assessment must be provided by a competent person, as this is critical for ensuring that an appropriate level of safety is achieved. Where there is not a suitable competent person within the organisation, this advice may be obtained from a qualified engineer with relevant experience in fire safety, including the fire testing of building products and systems, such as a Chartered Engineer registered with the UK Engineering Council by the Institution of Fire Engineers.
- 3.3. If advice is required, there remains a need to consider a holistic overview of the general fire precautions, even if advice may be needed from several different sources, depending on what aspect of the fire precautions is being considered.
- 3.4. Where the assessment is more straightforward then a fire risk assessor may be a more appropriate individual. Guidance on selecting a fire risk assessor is provided within the Local Government Association guidance 'Fire safety in purpose built-blocks of flats' in Appendix 3 and the Fire Risk Assessment Competency Council document 'Guide to choosing a competent fire risk assessor', which details two methods of demonstrating competence.
- 3.5. The Responsible Person and/or the competent person will need to ensure that the individuals who will be implementing the interim mitigation measures will also need to have a level of knowledge and understanding of the proposals so that they can operate effectively.

4. Changing to an evacuation strategy

Reasons for changing to an evacuation strategy

- 4.1. As detailed in the introduction above, the strategy in a residential building typically comprises a stay put strategy. However, in exceptional circumstances it may be necessary to temporarily change the evacuation strategy from stay put to simultaneous evacuation.
- 4.2. A stay put strategy relies on the fire separation between each flat to ensure that the fire does not spread throughout the building unrestricted and uncontrolled. This fire separation is achieved through different means such as fire-resisting doors, fire-resisting walls separating flats, and ensuring that the external walls of the building adequately resist the spread of fire over the walls.
- 4.3. Buildings that have, for example, been identified as having an external wall system that does not adequately resist the spread of fire over the walls (e.g. ACM identified as hazardous by DCLG because of large scale fire tests carried out on their behalf) is one example of circumstances where a simultaneous evacuation strategy may be needed.
- 4.4. In these circumstances, the change to a simultaneous evacuation strategy must not be permanent. It should always be considered as an interim mitigation measure, adopted for the safety of residents while works to rectify the identified fire safety failings are carried out.
- 4.5. In addition, it must be acknowledged that the move to a simultaneous evacuation may not address all the risks identified and be considered to mitigate all general fire precaution failings (e.g. deficiencies in means of escape). The responsible person must always discuss the change of evacuation strategy with a competent person, who can further advise on the proposal, including any limitations of such a change, and evaluate the overall fire safety provisions of a building.

General requirements of a temporary simultaneous evacuation

- 4.6. Where a temporary simultaneous evacuation strategy is adopted, the responsible person must notify the FRS, as it may need to amend its operational procedures.
- 4.7. The common alarm/on-site staff should only be removed when the required remedial works have been completed, a competent fire safety specialist has been consulted and the FRS have been notified that the evacuation strategy has ceased and the building has returned to the stay put strategy.
- 4.8. A change to a simultaneous evacuation strategy relies on two key essential principles:
 - Early detection of a fire and warning of occupants
 - Management of the evacuation.
- 4.9. It is the duty of the responsible person to ensure that both are appropriately considered and addressed as part of the simultaneous evacuation.
- 4.10. A change in evacuation strategy will require careful consideration of how people are warned of a fire. This means that, at the earliest opportunity, a fire should be detected and warning given throughout the building.
- 4.11. Flats that do not have their own smoke alarms should be fitted with them, regardless of the other fire safety provisions in the building.
- 4.12. The early detection of a fire may be through either:

- A Waking Watch using trained staff to assist with detecting a fire, and raising the alarm (see Appendix 1 for further guidance on this topic);
 - A Common Fire Alarm system throughout the building with detectors and sounders in all areas (see Appendix 2 for further guidance on this topic);
 - Or, ideally, a combination of both.
- 4.13. The management of the evacuation is another key part of this significant change as it will allow a rapid, effective and coordinated evacuation, as well as provide an essential link with the FRS. It will most likely rely on the use of on-site staff who will be able to facilitate the evacuation (see paragraph 5 for further information about the management considerations).
- 4.14. Consideration should be given to the capacity of the staircase and whether it is able to accommodate the expected population in the building. This is not expected to be an issue in most cases.

Information to residents

- 4.15. It is essential that residents are informed of the reasons for the change of the evacuation strategy, the purpose of it, and what actions will be taken in the event of a fire. It is unlikely that relying on a simple mail drop or information on communal notice boards will be sufficient. Resident meetings supported with written advice are more appropriate and should be supplemented by staff (for example, representatives of the responsible person) proactively engaging with residents to ensure that they understand the situation and any subsequent changes/works that might be happening. In engagement with residents, priority should be given to vulnerable people.
- 4.16. It is important that, as part of this process, occupants understand the evacuation strategy as well as the evacuation procedures and what action they should take upon leaving the building. Instructions should also be given to prepare residents for any simultaneous evacuation by advising they pre-pack a 'grab-pack' of relevant (warm) clothing and personal possessions, in case they are asked to remain outside of their flat or building for some time.

5. Management considerations to support the adoption of an evacuation strategy

- 5.1. As detailed above, any evacuation strategy must be supported by appropriate managerial arrangements. The following paragraphs give further guidance about the management considerations that should be put in place to support this change.
- 5.2. It is recommended that every building should be provided with 24/7 on-site staff whose role will be to:
- Call the FRS as soon as possible and provide key information about the building;
 - Manage the evacuation as necessary, including directing residents to a dedicated assembly point;
 - Liaise with the attending FRS to provide information as necessary.
- 5.3. The number of staff required in individual buildings will vary. Advice should be sought from a competent person to advise accordingly.

- 5.4. Following the identification of a confirmed fire, the on-site 24/7 staff should:
- Instigate a simultaneous evacuation of all occupants of the building without compromising the personal safety of staff;
 - Ensure that the fire service is called immediately; such is the importance of this action that one member of staff should be tasked with ensuring that this action has been taken, whether by that person or one of the other members of staff;
 - Reduce as far as reasonably practicable the evacuation time;
 - Facilitate the evacuation of vulnerable people through PEEPs.

Calling the Fire Service

- 5.5. In the event of fire, the on-site staff will make an immediate call to the FRS by dialing 999, stating:
- The address of the premises;
 - The total number of floors of the building;
 - Where the fire has started i.e. flat number and floor or externally;
 - That a simultaneous evacuation is under way;
 - Where known, the number and location of any vulnerable people who may not be able to self-evacuate
 - Any other information as relevant.
- 5.6. It will normally be appropriate for one member of staff to meet the FRS on arrival to pass on relevant information.

Vulnerable residents

- 5.7. All residents should be surveyed in respect of their ability to evacuate the building without assistance. In each case where a resident is identified as being unable to respond to the evacuation signal and/or unable to self-evacuate, the Responsible Person should, subject to the co-operation of the residents, seek to agree a PEEP with each of these residents. The level of on-site staff, training, equipment and evacuation protocols must fully reflect a simultaneous commitment to all the PEEPs as well as the general evacuation in the building.
- 5.8. The staff member designated to meet the FRS on their arrival must be able to report information on each resident for which a PEEP has been agreed but is not yet accounted for, namely:
- The flat number and floor of the resident;
 - The assistance required by the resident.
- 5.9. Vulnerable residents who cannot be assisted to safety may need to be relocated while this simultaneous evacuation strategy is in place. However, this would require the co-operation of the residents in question.
- 5.10. Information on residents who may need assistance to evacuate could be kept in a premises information box that is readily available to a fire and rescue service.

General housekeeping

- 5.11. Whilst undertaking their patrols, the on-site management staff should:
- Remove any combustible items stored inappropriately;
 - Ensure that all fire-resisting doors are kept shut, and locked shut, where required (e.g. riser cupboard doors);
 - Provide reassurance to residents of the building;
 - Report any concerns to the Responsible Person for the building.

Staff facilities

- 5.12. Welfare/Toilet facilities should be considered for the well-being of the staff, such as washing, toilet, rest and changing facilities, and somewhere clean to eat and drink during breaks.
- 5.13. Staff should be clearly identified in high visibility clothing. The different roles (i.e. staff, team leaders) should be identified by the clothing or markings. Staff may also need other equipment such as a torch to ensure they can perform their role.

Staff training & communications

- 5.14. Training should be given to staff to ensure they fully understand the purpose of their role and what individual tasks they are responsible for both during normal hours and in the event of a fire. They should also be given general health and safety training, and specific fire training to support safe systems of work.
- 5.15. Specific instruction should be provided on the communication processes amongst the waking watch team, and how to ensure that they do not place themselves or others at risk.
- 5.16. It is not advisable to expect staff to actively engage in first aid fire-fighting.
- 5.17. Training will need to be repeated if any of the staff members change and further training if any arrangement changes. All staff should receive regular refresher training.
- 5.18. It is important that staff can instantly and constantly communicate with each other. The method of communications must be available throughout the building. Radios are often the most appropriate way of achieving this and must be supported by an appropriate radio protocol – this may include a set words for checking in, raising the alarm etc. Radio traffic should be kept to a minimum to ensure that the system is available for appropriate communications. The adequacy and effectiveness of radio communication throughout the building should be tested and confirmed.
- 5.19. It is unlikely that mobile phones will provide an appropriate method of communications between staff. These require more than just a single button actuation, and will not be available for the instant and simultaneous relay of messages to multiple staff. Mobile phones also rely on being connected to a network and this may not always be possible.

Test of the process

- 5.20. The process should be tested in the form of regular staff training exercises to ensure that all staff understand their roles and that the system is appropriate for the specific building. However, where this is required, it will not usually be necessary to sound the evacuation signal (air horns etc.) every time as this may lead to complacency by the residents. Residents should not be involved in these staff training exercises, but should have been made aware of the necessary action if the evacuation signal is given.

- 5.21. Staff training exercises should be recorded and immediately available on site to the FRS for inspection.
- 5.22. The Responsible Person needs to ensure that there are arrangements for adequate monitoring of the waking watch team.
- 5.23. In every building where an evacuation strategy is adopted, the FRS will make regular visits to ensure that the arrangements in place are being robustly implemented and managed.

Fire risk assessment

- 5.24. The fire risk assessment for the premises, and its associated evacuation plan must be updated to reflect the issues identified, the role of the waking watch and the duration of the temporary mitigation measures in place.

Health and safety

- 5.25. It is vital that any processes and procedures put in place allow compliance with other applicable legislation such as Health and Safety at Work Act 1974, and the Management of Health and Safety at Work Regulations 1999. The procedures developed must never jeopardise the safety of staff

6. Responsible person duties

- 6.1. The responsible person duties are laid out in Part 2 of the Regulatory Reform (Fire Safety) Order 2005.
- 6.2. The Responsible Person must ensure that the adoption of an evacuation strategy relies on the assessment of a competent person and addresses the risks identified.
- 6.3. The responsible person must ensure that the mitigation measures put in place always remain appropriate.
- 6.4. The responsible person must ensure that appropriate resources are allocated to address the specific risk identified in the building.
- 6.5. The evacuation strategy must be re-evaluated periodically as the remedial works are being carried out to ensure that it remains current and addresses the general fire precaution failings.
- 6.6. For further general fire safety advice, please contact your local FRS fire safety team.

It may be that, even if all the above guidance were to be implemented, the risk is not reduced enough to enable all the persons to remain in the property, and certain uppermost floors might need to be temporarily evacuated. There should be liaison with the FRS in respect of this matter.

Appendix 1 Waking Watch guidance

Purpose of the waking watch

A1.1 The purpose of a waking watch as described by this guidance is to:

- detect a fire in the building;
- detect external fire spread if combustible cladding/insulation materials have been identified as part of the external wall system;
- summon the FRS;
- ensure all residents are alerted to begin simultaneous evacuation;
- take appropriate action as required by the management strategy, including meeting the FRS on arrival.

A1.2 Once it has been decided that a waking watch is appropriate, the details of what staff will be required to do, their numbers and their training should be determined.

A1.3 It is very difficult to precisely determine the appropriate number of staff for a waking watch for every building - the purpose of this guidance is to provide generic advice. As a benchmark, the objective should be that when a confirmed fire within a flat necessitates simultaneous evacuation, the time from detection of the fire to alerting all residents (whether by the waking watch or by a common fire alarm system) and confirming evacuation has started, should not exceed a time of typically 10-15 minutes in the case of an external wall system that represents a significant fire hazard (e.g. polyethylene core ACM, defined as Category 3 in the Government cladding screening programme).

The 10-15 minute estimate is not appropriate for major breaches in compartmentation, in which case the time from detection of the fire to alerting all residents and confirming they are evacuating, should be significantly less than this figure.

A1.4 There are three possible approaches:

- a) Installation of a common fire alarm system of the type described in Appendix 2. In this case, the objective of the waking watch no longer comprises detection of fire or alerting residents. The role of the waking watch is purely to summon the FRS and manage the evacuation process. For this purpose, only a small number of staff is likely to be required in any building; there would not be any need for sufficient staff to patrol the building such that each floor was inspected within any given period. This is the preferable approach where an external wall system that represents a significant hazard on buildings over 18m in height cannot be replaced or removed in the short term.
- b) Reliance on the waking watch to detect the presence of a fire, and manually to initiate fire alarm sounders that would alert all residents of the need to evacuate. This will initially involve provision of sounders throughout the common parts, but, ultimately, is likely to need a sounder in every flat to ensure that the fire alarm signal is loud enough to rouse residents from sleep. The manual initiation of sounders would comprise, at least, one manual control on the ground floor that triggers operation of all sounders, but could comprise manual controls on additional floor levels. The method of operation of the manual controls should be such that they can only be operated by staff or FRS. In this case, the number of staff on the waking watch should be such that they become aware of a fire (e.g. by hearing a smoke alarm operate and immediately investigating) and operate a manual control within 10-15 minutes of operation of a smoke alarm within a flat.

- c) Reliance on the waking watch to detect the presence of a fire and to take manual action to alert residents of the need to evacuate (e.g. knocking on each flat front door and/or using an air horn to alert residents). In this case, there will, again, need to be sufficient staff on the waking watch, such that they become aware of a fire (e.g. by hearing a smoke alarm operate and immediately investigating) and then alerting all residents within 10-15 minutes of operation of a smoke alarm within a flat. This alternative is likely to be the least reliable, most resource intensive, and may not be suitable for the highest risk situations.

NOTE: Care should be taken (e.g. in the training of the Waking Watch staff) to ensure that they do not initiate a simultaneous evacuation in the event of a false alarm from a domestic smoke alarm, or a small fire that has been extinguished.

A1.5 While the above information is offered as a benchmark, the solution adopted by a competent person should consider many factors, including (but not necessarily limited to) the following:

- The fire and rescue service attendance time
- The general fire precautions in the building
- The height of the building
- Provision of sprinklers or other automatic fire suppression systems
- The number of flats
- The type of cladding (i.e. Category 2 or Category 3)
- The extent of the cladding
- The number of means of escape stairways
- The proximity of the cladding to windows or vents within common parts, particularly the stairway(s)
- Risk of external ignition of cladding (e.g. taking into account the height at which the cladding starts, proximity of cars etc. to the cladding)
- Risk of internal ignition of cladding (e.g. from fires inside the building via unprotected window reveals and the proximity of ignition sources such as domestic appliances)
- The collective effect of the fire safety measures considered holistically, as opposed to each measure in isolation.

Appendix 2 : Common Alarm System: Automatic fire detection and alarm system supporting simultaneous evacuation

Purpose

- A2.1 The purpose of the provision of a common fire alarm to support the change of the evacuation strategy from stay put to simultaneous evacuation is to ensure early detection of a fire throughout the building (including any accommodation e.g. individual flats).
- A2.2 As described above, the common fire alarm system cannot be implemented in isolation and must be provided as part of a package of fire safety measures. The aim of the guidance below is to provide and highlight some of the key considerations about the selection and implementation of a common alarm system.

System design and considerations

Location and coverage of the detection system

- A2.3 Considering the specific purpose of this guidance, the common fire alarm system should generally be designed in accordance with the recommendations of BS 5839-1 for a Category L5 system, except that the sound pressure level of the fire alarm signal within flats need only be 85dB(A) at the open doorways of every bedroom in each flat.
- A2.4 The system should incorporate heat detectors within each room in every flat that has a window that overlooks an area of external wall with an external wall system material that results in a significant or notable fire hazard (except possibly toilets and bathrooms). Heat detectors should also be included in any other rooms, such as plant rooms and other ancillary facilities with windows or vents through which a fire could spread and ignite cladding. Consideration might also need to be given to the provision of smoke detectors within common parts, but these detectors should not initiate the general evacuation of the building; they may give a warning only to the waking watch team.
- A2.5 An immediate evacuation signal should be triggered by the operation of any single heat detector. It should be noted that the evacuation signal should not rely on the coincident operation of two heat detectors (sometimes described as “double knock”), as such an arrangement would not result in early enough operation of the evacuation signal in the event of a serious fire that might affect cladding.
- A2.6 In line with the individual PEEP process, specific measures such as a vibrating pager or beacon may be required if people with hearing impairments have been identified.
- A2.7 It is critical that the common alarm system installed in the premises must not have any adverse effect on the other fire safety provisions in the building. For example, the installation of a wired system must not create a route for fire and smoke to spread in fire rated walls which were previously good.

This guidance was produced for the National Fire Chiefs Council by a group of sector experts, comprising:

Nick Coombe, representing NFCC

Sir Ken Knight, representing the DCLG Independent Expert Advisory Panel

Colin Todd, representing the Fire Industry Association and the Institution of Fire Engineers

Colin Bassnett, representing the Fire Industry Association

Andrew Fox, representing the Fire Industry Association

Tom Gilbert, representing the Fire Industry Association

John Herbison, representing the Institution of Fire Engineers

David Rowson, representing London Borough of Southwark

Gareth Steele, representing London Fire Brigade

NFCC also acknowledge the work of Ann Clarke of C. S. Todd & Associates in providing secretarial support and the wider NFCC Protection & Business Safety Committee for their comments.

SSHD/3



Ministry of Housing,
Communities &
Local Government

The Rt James Brokenshire MP
*Secretary of State for Housing, Communities and
Local Government*

**Ministry of Housing, Communities and Local
Government**

4th Floor, Fry Building
2 Marsham Street
London SW1P 4DF

Tel: 0303 444 3450

Email:

james.brokenshire@communities.gsi.gov.uk

www.gov.uk/mhclg

21 May 2018

Dear John,

Building Safety Programme: Stay Put Policy

During today's Urgent Question on tower blocks with dangerous cladding, you raised questions about fire and rescue service advice on 'stay put' policy and the advice to building owners and residents in circumstances where 'stay put' policy was suspended.

'Stay put' is an operational policy overseen by fire and rescue services. The National Fire Chiefs Council has issued a statement on this, which can be found at:

<https://www.nationalfirechiefs.org.uk/News/national-fire-chiefs-council-reiterate-stay-put-advice/200686>

Existing advice on the policy and guidance about its suspension in certain circumstances is annexed to this letter and can be found on the National Fire Chiefs Council website at:


<https://www.nationalfirechiefs.org.uk/Simultaneous-evacuation-guidance>

Following the Grenfell Tower tragedy, the Government worked with fire safety experts, including the National Fire Chiefs Council, to issue advice to owners of high rise residential blocks of flats with unsafe cladding on the immediate steps they should take to mitigate the risks of fire and maintain the safety of their buildings for residential use, pending full remediation work. This advice has been supported by fire and rescue service inspections of all buildings identified as having unsafe cladding.

To support that advice, the National Fire Chiefs Council issued more detailed guidance to fire and rescue services and building owners on the arrangements that should be in place where a 'stay put' policy has been suspended. That guidance was issued in October 2017. The National Fire Chiefs Council published an updated version of the guidance in May which did not alter the existing position on the maintenance or suspension of 'stay put' policy.

Decisions on maintaining or suspending the 'stay put' policy in blocks of flats should be based on a comprehensive risk assessment undertaken by a competent fire risk assessor. Residents and the local fire and rescue service should be informed where an existing 'stay put' policy is suspended.

This Government is committed to ensuring that buildings are safe and that residents feel safe.

A handwritten signature in black ink, appearing to read 'James Brokenshire', written in a cursive style.

RT HON JAMES BROKENSHIRE MP

ANNEX: Simultaneous evacuation guidance

Guidance: to support a temporary change to a simultaneous evacuation strategy in purpose-built blocks of flats

In early October 2017 the National Fire Chiefs Council published 'Waking Watch/Common Fire Alarm' guidance, to provide advice to building owners, their professional advisers and Fire and Rescue Services (FRS) to support a temporary change to simultaneous evacuation.

Following a commitment to review the guidance after six months, in February 2018 the National Fire Chiefs Council invited user feedback and held a workshop with external stakeholders to assess if the document is still fit for purpose. The guidance has undergone some amendments based on stakeholder feedback to make it clearer and more user-friendly.

The new version - published today - is titled 'Guidance: to support a temporary change to a simultaneous evacuation strategy in purpose-built blocks of flats'. This document replaces the original Waking Watch guidance published in October 2017.

It is to be used where a decision has been made to adopt such a strategy - based on a comprehensive risk assessment - carried out by a competent person.

The main edits are:

- Amendments to clarify and highlight the intention that a Waking Watch is only a short-term solution and a fire alarm system should be installed if the risk cannot be removed quickly
- There is further guidance on the information a competent person should consider in a risk assessment.
- To clarify that the risks to persons should be considered regardless of whether the building is above or below 18m in height.

NFCC supports the principle of a Stay Put strategy whenever possible, as it has been proved over many years to be safe for residents of purpose-built blocks of flats. NFCC believes that a Stay Put strategy is the correct advice in a purpose-built block of flats that is built and maintained correctly. In a building that was originally designed for a stay put policy, a change to simultaneous evacuation should only be temporary until the risk has been removed.

This guidance applies to premises in England and Wales. It was produced to support FRSs, building owners/responsible persons and associated fire safety specialists, including fire risk assessors.

This guidance is applicable to buildings which have been fitted with an external wall system which failed the large-scale tests commissioned by the then Department for Communities and Local Government (now the Ministry of Housing, Communities and Local Government) following the Grenfell Tower fire, carried out at the Building Research Establishment (BRE).

Although written for those responsible for the safety of residents in purpose-built blocks of flats, the principles of this guidance may, in certain circumstances, be applied to other premises.

NFCC supports the 'Fire safety in Purpose Built Block of Flats' guidance hosted on the LGA website and developed by a wide range of stakeholders. The guidance remains appropriate for all purpose-built blocks of flats.